

**NOTIFICATION OF THE PRESENCE OF ASBESTOS IN BUILDINGS AT CALIFORNIA STATE UNIVERSITY, NORTHRIDGE
JANUARY 2024**

This notification is being provided to University employees pursuant to the requirements of California Health and Safety Code, Section 25915. As part of building renovation projects, a majority of the asbestos containing construction materials (ACM) have been removed from campus buildings. Despite these efforts, ACM may still exist in some buildings. For your information, a list of building locations and a brief description of the materials which are known to contain asbestos can be found below.

ACMs were identified via surveys that may have included detailed building inspections, material sampling, and laboratory analysis. The sampling and laboratory procedures utilized in conducting these surveys included National Institute for Occupational Safety and Health (NIOSH) and Environmental Protection Agency (EPA) methods. ACMs pose no threat to your health unless the asbestos fibers become airborne due to deterioration, or as a result of damage. Therefore, it is important that proper work practices be followed to minimize the potential for disturbing asbestos-containing construction materials. Avoid touching or disturbing asbestos materials on ceilings, pipes, and duct insulation. If you find ACM that has been damaged, immediately report the condition to Environmental Health and Safety at extension 2401. Do not disturb damaged ACM or asbestos debris. Only authorized and properly trained individuals may perform any work which may disturb ACM.

If you have any questions or wish to review the asbestos surveys and specific sampling procedures, please contact EH&S at extension 2401 during normal business hours.

BUILDING	LOCATION	SPECIFIC ASBESTOS CONTAINING MATERIALS
Black House	Attic / Rooms 4, 5	Heating duct insulation, vent pipe(s), floor tile and mastic
Green House	Windows / Roof	Thermal pipe insulation , Glazing compound (putty); Weather stripping, Transite panels
Citrus Hall	Laboratories	Fume hood panels
Chicano House	Roof	Roofing materials and mastic
Child and Family Studies Lab School	Attic, Kitchen / Restroom / Windows	Floor tile and mastic, Glazing compound (putty), heating duct insulation
Cypress Hall	General mechanical rooms / maintenance access areas throughout the building	Thermal pipe insulation, Tank insulation
Eucalyptus Hall	Laboratories, mechanical rooms / maintenance access areas throughout the building	Fume hood panels, thermal pipe insulation
Eucalyptus Hall	Rooms 2202, 2205	Thermal pipe insulation
Jacaranda Hall	General mechanical rooms / maintenance access areas throughout the building	Thermal pipe insulation
Jerome Richfield Hall	General mechanical rooms / maintenance access areas throughout the building	Thermal pipe insulation
Laurel Hall	Telecom Room-Class 1	Floor tile and mastic
Live Oak Hall	Laboratories, mechanical rooms / maintenance access areas throughout the building	Fume hood panels, thermal pipe insulation
Matador Bookstore Complex	Penthouse mechanical room / various rooms	Chilled water (HVAC) thermal pipe insulation, Floor mastic
Fitness Center / Nautilus	Restroom / Room 101	Floor tile and mastic, wallboard/joint compound/plaster/mirror mastic
Nordhoff Hall	General mechanical rooms/ maintenance access areas throughout the building / orchestra pit/ basement hallway/ first floor hallway	Thermal pipe insulation, tank insulation
Nordhoff Hall	Rooms 200, 220, 220A, 221	Floor tile and mastic
University Library	Chiller room / basement	Thermal pipe insulation, tank insulation, floor tile and mastic
Redwood Hall	General mechanical rooms / maintenance access areas throughout the building	Thermal pipe insulation
Sierra Hall	General mechanical rooms / maintenance access areas throughout the building	Thermal pipe insulation, floor tile and mastic
Sierra Tower	General mechanical rooms / maintenance access areas throughout the building	Thermal pipe insulation
Jacaranda Hall	Underground	Thermal pipe insulation
Orange Grove Bistro	Throughout building and underground	Drywall mud and thermal pipe insulation
Student Health Center	Storage Rooms	Tile and mastic